



Sealtite Type UA-CSA: UL & CSA Approved Flexible Conduit



Trade Size	Item ID	Std. Pkg. METERS	Inside Diameter Min	Outside Diameter		Bend Diameter	Weight (Kg) Per Meter
				Min	Max		
3/8" (12)	34202	30	12.29 (0.484)	17.50 (0.690)	18.00 (0.710)	152 (6.0)	0.47
1/2" (16)	34212	30	15.80 (0.622)	20.80 (0.820)	21.30 (0.840)	178 (7.0)	0.53
	34213	305					
3/4" (21)	34222	30	20.83 (0.820)	26.17 (1.030)	26.67 (1.050)	254 (10.0)	0.73
	34228	152					
1" (27)	34231	30	26.44 (1.041)	32.80 (1.290)	33.40 (1.315)	318 (12.0)	1.30
	34238	122					
1-1/4" (35)	34241	15	35.05 (1.380)	41.40 (1.630)	42.20 (1.660)	356 (14.0)	1.73
	34248	76					
1-1/2" (41)	34251	15	40.01 (1.575)	47.40 (1.865)	48.30 (1.900)	279 (11.0)	1.86
	34254	45					
2" (53)	34261	15	51.31 (2.020)	59.40 (2.340)	60.30 (2.375)	356 (14.0)	2.20
	34268	30					
2-1/2" (63)	34075	8	62.99 (2.480)	72.10 (2.840)	73.00 (2.875)	635 (25.0)	2.88
3" (78)	34085	8	77.98 (3.070)	87.90 (3.460)	88.90 (3.500)	762 (30.0)	4.00
4" (103)	34095	8	101.60 (4.000)	113.30 (4.460)	114.30 (4.500)	1016 (40.0)	6.00

All dimensions in mm (inches)

SPECIFICATIONS:

- Galvanized steel core with Liquid-tight PVC jacket
- Colour: Grey (2-1/2" - 4" Black)
- Temperature range: -20°C to +60°C
- UV (sunlight) Resistant
- Corrosion Resistant
- CSA Approved: #LL15275
- UL Approved: #E18917

APPLICATIONS:

- Applications where CSA and UL approvals are required.

Square Lock Design with copper wire 3/8" thru 1-1/4"



Interlocked Design 1-1/2" thru 2" (no ground wire)



Sealtite Type UA-CSA:



- Flexible metal core liquid-tight conduit
- Designed for applications at OEMs where UL & CSA approval is required or desirable.
- Approved in US (per NEC) for direct burial applications
- Suitable for use in hazardous locations per CEC & NEC: Class I, Zone 2 & Div. 2; Class II Div. 1 & 2; Class III Div. 1 & 2.
- Also available in Black by special order.
- Uses standard liquid-tight connectors for easy installation

For connectors for this conduit, see page 18-19
For cutting instructions, see page 33
For Chemical Resistance, see page 34